

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: RC-NO-25/SPL/2026

Dated: 10/06/2026

It is certified that an inspection team headed by M. Srinivasa Rao

(Name of Officers with designation) from PHC Digavalli PHED

inspected the Bethesda Integrated school, Boravanchara villege, Nuzvid

(Name & Address of the School) on 10/06/2026 (Date of Inspection) and on the basis of

Water Test Report (Attached) bearing No. P-59-C & P-59-B dated 04-04-2026

of Distric public laboratory, ELURU (PHED Lab), certified that the

Bethesda Integrated school (Name of School) has safe drinking water

facilities for the students and members of staff of the institution. The school also maintains the

hygienic sanitation condition in the school building and the campus as per norms prescribed by the

Central/State/U.T. Government.

This certificate is valid till 09/06/2027.


Signature with Seal:

Name:

Designation:

Name & Address of
the Office /

Department:


MEDICAL OFFICER
DR. P. C. SRINIVASA RAO
PHC DIGAVALLI
NUZVID, ELURU DIST
MEDICAL OFFICER
PHC DIGAVALLI

To

Bethesda Integrated school,
Boravanchara villege, Nuzvid.

(Name & Address of the Institution)

Note: The Certificate Is to Be Issued by Authorized Officer/PHED Lab /Local Bodies



SANITARY CERTIFICATE FOR THE YEAR 2025-2026


RC- NO - 25/SPL / 2026. Dt. 10-06-2026

This is to certify that, I have visited and inspected Bethesda High School building & premises R.S No-227/1 situated in Borvancha gramapanchayat , Nuzvid rural mandal, Eluru district on

The accommodation provided for each of the several classes are sufficient for maximum number of pupils taught. The school is properly ventilated and lighted. The building is maintained in the substantial repair and it is neat and clean. School provides separate toilets for girls, boys and also ladies, gents staff are adequate and satisfactory. School management is taking all necessary precautions to maintain health and hygiene of the students. The supply of drinking water is whole some and sufficient, in public point of view the sanitation is Satisfactory.

Station:- Digavalli

Date:-


MEDICAL OFFICER
P.H.C., DIGAVALLI
NUZVID, Eluru Dist



BETHESDA INTEGRATED SCHOOL

CBSE affiliation No. 130478 & School Code No. 57180

Konnamgunta Road, Boravancha Village, Nuzvid Mandal 521201., A.P, India
8142 344 445 | 9666 400 500 | email: bis.bethesda@gmail.com

Nuzvid,

Date:15-04-2025.

To
The Secretary,
CBSE,
Delhi.

"Subject: Purchase of koyyala raghavaiah charitable trust

We are pleased to inform you that Bethesda Integrated School, affiliated with CBSE (Affiliation: 130478), located on Konnamgunta Road and Boravancha Road in Nuzvid, is now purchasing koyyala raghavaiah charitable trust water for our water supply.


In our commitment to maintaining the highest standards of hygiene and quality within our premises, we have enclosed the water laboratory testing certificate for your review and records.

This purchase reflects our dedication to providing a safe and conducive learning environment for our students.

Thank you for your attention to this matter.



PRINCIPAL
BETHESDA HIGH SCHOOL
Konnamgunta Road, BORAVANCHA (V)
Nuzvid Mandal, PIN - 521 201



CORRESPONDENT
BETHESDA HIGH SCHOOL,
Konnamgunta Road, BORAVANCHA (V),
NUZVID (Md.), - 521 201.

GOVERNMENT OF ANDRAPRADESH
DIRECTORATE OF INSTITUTE OF PREVENTIVE MEDICINE, FOOD (H) ADMN, Amaravathi, A.P
District Public Health Laboratory, Kotadibba-ELURU-534001

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	Koyyala Raghavaiah Charitable Trust, D.No.7-158, Nuzvid, Eluru District.	Lab Ref.NO:	P-59-C & P-59-B
		Collected on:	05. 03. 2024
		Received on:	05. 03. 2024
Collected By	Self	Source profile	R O Water at Plant

S.No.	Parameter	Result	Limits as per IS 10500:2012	
			Desirable (acceptable limit)	Permissible limit in the absence of alternative souece
1	Colour	Colourless	5	10
2	Turbidity	0.4	1	5 NTU
3	Odour	Odourless	--	--
4	p ^H	7.0	6.5-8.5	No Relaxation
5	Electrical Conductivity at 25 ^o c Micro Mhos/cm	120	--	--
6	T.D.s (Mg.L)	79	500	2000

Chemical Parameters (Mg/L)

1	Phenolphthalein Alkalinity as (caco ₃)	Nil	--	--
2	Total Alkalinity	32	200	600
3	Total Hardness	28	300	600
4	Calcium Hardness as (caco ₃)	08	--	--
5	Magnesium Hardness	20	--	--
6	Calcium (as Ca)	3.2	75	200
7	Magnesium	5.856	30	100
8	Ammonical Nitrogen	Nil	--	--
9	Nitrite (as. N.)	Nil	--	--
10	Sulphates (as So ₄ .)	Nil	--	--
11	Chloride (as Cl.)	36	250	1000
12	Fluoride (as F.)	0.1	1	1.5
13	Iron (as Fe.)	Nil	0.3	No Relaxation

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1	Residual Chlorine	Nil	Nil (ppm)	Nil
2	MPN of E Coliform bacterial in 100 ml	Nil	Nil	Nil
3	H ₂ S Valais strip test	---	---	---
4	MPN of Coliform organism in 100 ml	Nil	Nil	Nil

Remarks: All the Physico & Chemical characteristics are within the Desirable limits for drinking purpose.,

The Lab Ref.No.P-59-B is Bacteriologically Satisfactory for drinking purpose as the MPN Count Is Nil.

BETHESDA HIGH SCHOOL
 Konnamgunta Road, BORAVANCHA (V)
 NUZVID (Md.), - 521 201.



PRINCIPAL
BETHESDA HIGH SCHOOL
 Konnamgunta Road, BORAVANCHA (V)
 Nuzvid Mandal, PIN - 521 201